

Log No. 41482
 Permit No. 218
 Basin 218

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

MW-8

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10149

1. OWNER NEVADA POWER Co. ADDRESS AT WELL LOCATION NEVADA POWER Co.
 MAILING ADDRESS 96 CONVERSE CONSULTANTS REID GARDNER STA. P.O. BOX 77
4670 S. POLARIS Av., LV, NV 89103 MOAPA, NV 89025
 2. LOCATION NW 1/4 SE 1/4 Sec. 5 T 15 N 66 E CLARK County
 PERMIT NO. MO-2264 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other... AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
FILL - GRAVELLY SAND		0'	3'	3'
SILTY CLAY WITH GRAVEL		3'	6'	3'
SILTY CLAY		6'	8'	2'
CLAY		8'	10'	2'
GRAVELLY CLAY		10'	12'	2'
CLAY		12'	15'	3'
GRAVELLY CLAY		15'	22'	7'
CLAY WITH GRAVEL		22'	24.5'	2.5'
CEMENTED GRAVELLY SAND		24.5'	30'	5.5'

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased _____ Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches 0 Feet 30 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	2 lbs	SCH 40	0	30

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 0.020
 From 20 feet to 30 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0-16/10-16 BENT Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 16 feet to 30 feet

RECEIVED
 MAY 06 1993
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 4-15 1993
 Date completed 4-15 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 18 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name RICHARD LEBLANC Contractor
 Address 4670 S. POLARIS AV. Contractor
LAS VEGAS, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1817
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 05-03-93