


Log No. 41494  
 Permit No. \_\_\_\_\_  
 Basin 230



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT No. 10869

1. OWNER JEANNIE MCALISTER ADDRESS AT WELL LOCATION DIABALO RD AMARGOSA VALLEY  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION S.W 1/4 NE 1/4 Sec. 19 T. 16 S N/S R 48 E N.YE County \_\_\_\_\_  
 PERMIT NO. 19-071-11 Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM + GRAVEL		0	12	12
SAND + GRAVEL		12	17	5
CLAY + GRAVEL		17	80	63
CLAY		80	95	15
SAND + GRAVEL	W.B.	95	120	25
CEMENTED SAND + GRAVEL w/ FRACTURES	W.B.	120	135	15

8. WELL CONSTRUCTION  
 Depth Drilled 135 Feet Depth Cased 135 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 0 Feet 135 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>135</u>

Perforations:  
 Type perforation FACTORY SAW CUT  
 Size perforation 8 INCH BY 3 INCH  
 From 135 feet to 115 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 135 feet to 50 feet

RECEIVED

MAY 20 1993

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 5-12, 1993  
 Date completed 5-15, 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 9.5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING Contractor  
 Address HCR 78 BOX 80358 Contractor  
PAHRUMP NV. 89041  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 5-17-93

