


Log No. 41495

Permit No. \_\_\_\_\_

Basin 230



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT <sup>in book</sup>

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10016

1. OWNER ROBERT VAN NEYHOFF

ADDRESS AT WELL LOCATION WILLIAMSON RD. AMARGOSA NV.

MAILING ADDRESS \_\_\_\_\_

2. LOCATION SE 1/4 NE 1/4 Sec 8 T 16 S N1S R 49 E NYE County

PERMIT NO. 19-141-18

Issued by Water Resources

Parcel No.

Subdivision Name

3. WORK PERFORMED

- New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE

- Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE

- Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	8	8
SANDY LOAM + GRAVEL		8	35	27
CLAY		35	41	6
SAND + GRAVEL		41	77	36
CALICHE		77	88	11
SANDY LOAM + GRAVEL		88	198	110
SAND + GRAVEL	W.B.	198	205	7
CALICHE	W.B.	205	214	9
SAND + GRAVEL	W.B.	214	230	16

8. WELL CONSTRUCTION

Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

From		To	
Inches	Feet	Inches	Feet
<u>12 1/4</u>	<u>0</u>	<u>60</u>	<u>Feet</u>
<u>9 7/8</u>	<u>60</u>	<u>240</u>	<u>Feet</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>240</u>

Perforations:

Type perforation FACTORY SAW CUT  
 Size perforation 1 INCH BY 3 INCH

From	feet to	feet
<u>240</u>	<u>220</u>	<u>feet</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

RECEIVED

JUN 09 1993

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Surface Seal:

Yes  No

Seal Type:

Depth of Seal 50

- Neat Cement  
 Cement Grout  
 Concrete Grout

Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level 165 feet below land surface

Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.

Water temperature 60.2 °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING  
 Contractor

Address HCR 78 BOX 80358  
 Contractor

PAHRUMP NV. 89041

Nevada contractor's license number issued by the State Contractor's Board 30880

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573

Signed Donnie Brown  
 By driller performing actual drilling on site or contractor

Date 6-4-93



Date started 5-18, 1993  
 Date completed 5-22, 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)