

Log No. 41497
 Permit No. _____
 Basin 230



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT ^{in Book}

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11718

1. OWNER DANIEL & CRYSTAL MILLS ADDRESS AT WELL LOCATION AMARGOSA
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 NW 1/4 Sec. 36 T 16 S N/S R 49 E NYE County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|------------------------|--------------|------|-----|------------|
| SANDY LOAM | | 0 | 22 | 22 |
| CLAY & GRAVEL | | 22 | 118 | 96 |
| CEMENTED SAND & GRAVEL | | 118 | 129 | 11 |
| LIME STONE | | 129 | 140 | 11 |
| SAND & GRAVEL | W.B | 140 | 200 | 60 |

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 8 5/8 | 16.94 | .188 | 0 | 200 |

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 8 INCH BY 3 INCH
 From 200 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 200 feet to 50 feet

RECEIVED

APR 29 1993

Div. of Water Resources
 Branch Office - Las Vegas NV

Date started 4-16, 1993
 Date completed 4-20, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

9. WATER LEVEL
 Static water level 140 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING Contractor
 Address HCR 78 BOX 80358
PAHRUMP NV 89041 Contractor

Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573

Signed Donnie Brown
 By driller performing actual drilling on site or contractor
 Date 4-26-93

