


WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



Log No. 41535  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 10892

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER Ralph Schultz ADDRESS AT WELL LOCATION Bridger St  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SE 1/4 NW 1/4 Sec 14 T 21S N/S R 53 E Nye County  
 PERMIT NO. 44-734-06 Parcel No. Mesa Oeste Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	8	8
caliche		8	11	3
Clay		11	27	16
caliche		27	29	2
Clay		29	56	27
caliche	WB	56	60	4
Clay		60	90	30
caliche	WB	90	92	2
Clay		92	109	17
caliche	WB	109	111	2
Clay		111	124	13
caliche	WB	124	127	3
Clay		127	140	13

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/4</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation Factory Sawcut  
 Size perforation 1/8 x 3  
 From 0 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

RECEIVED

JUN 29 1993

Div. of Water Resources  
 Branch Office - Las Vegas, NV

9. WATER LEVEL  
 Static water level 54 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 6-7, 1993  
 Date completed 6-11, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Contractor  
 Address Hee 78 Box 80358 Contractor  
Palump NV 89041  
 Nevada contractor's license number issued by the State Contractor's Board 30886  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas Dan  
 By driller performing actual drilling on site or contractor  
 Date 6-19-93