

18607
OFFICE USE ONLY
Permit No. 41547
Basin

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23708

1. OWNER GAL-NEV PIPELINE CO.

ADDRESS AT WELL LOCATION GAL-NEV

MAILING ADDRESS % CONVERSE CONSULTANTS
4670 S. POLARIS AV, LV, NV 89103

5049 N. SILOAN LANE
LAS VEGAS, NV

2. LOCATION SUD 1/4, NW 1/4 Sec 34 T 19 N 03R 62 E CLARK County

PERMIT NO. MO-2258

Issued by Water Resources

Parcel No.

Subdivision Name

3. WORK PERFORMED
 New Well
 Replace
 Abandon
 Deepen
 Recondition
 Other

4. Domestic
 Municipal/Industrial

5. PROPOSED USE
 Irrigation
 Monitor
 Test
 Stock

6. WELL TYPE
 Cable
 Rotary
 RVC
 Air
 Other AUGER

LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILTY SAND		0	4	4
SANDY SILT		4	15	11
CLAYEY SILT		15	20	5
GRAVEL		20	21	1
CLAY		21	26	5
CEMENTED SILT & GRAVEL		26	28	2
SILTY CLAY		28	35	7
SANDY SILT		35	40	5
CLAY		40	109	69
SILTY CLAY		109	115	6
CLAYEY		115	118	3
CLAY		118	127	9

TD=127

8. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
127		127	

HOLE DIAMETER (BIT SIZE)

Inches	From	To
8	0	127

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	7.7 lbs	SC4	40	0
			0	127

Perforations: FACTORY SLOTTED
Type perforation D.020"
Size perforation 125
From.....feet to.....feet 127
From.....feet to.....feet
From.....feet to.....feet
From.....feet to.....feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 0-122/120-122 BEAUT. Cement Grout
Placement Method: Pumped Concrete Grout
 Poured
Gravel Packed: Yes No
From.....feet to.....feet 122 127 feet

9. WATER LEVEL
Static water level.....feet below land surface 100
Artesian flow..... G.P.M. P.S.I.
Water temperature.....°F Quality.....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name RICHARD LEBLANC Contractor
Address 4670 S. POLARIS AV. Contractor
LAS VEGAS, NV 89103



Nevada contractor's license number
Issued by the State Contractor's Board.....
Nevada driller's license number issued by the M-1817
Division of Water Resources, the on-site driller

Signed [Signature]
By driller performing actual drilling on site or contractor
Date 6-18-93

7. WELL TEST DATA
Date started MAY 19 1993
Date completed MAY 19 1993

TEST METHOD: Bailor Pump Air Lift
G.P.M. (Feet Below Static) Time (Hours)