WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41590
Permit No.
Basin 212

NOTICE OF INTENT NO. 10752

1. OWNER NATIONAL GROUNDWATER ASSOC.
MAILING ADDRESS 6375 RIVERSIDE DR.
DUBLIN, OHIO 43017

ADDRESS AT WELL LOCATION
NW CORNER OF PARADISE & RIVIERA
LAS VEGAS, NV

2. LOCATION SE ¼ NE ¼ Sec. 9 T. 21 N/S R. 61 E. CLARK County

PERMIT NO. MO-2289 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE DEMONSTRATION
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILTY SAND		0	1	1
CLAYEY SAND		1	2	1
SILTY CLAY		2	5	3
CALICHE		5	6	1
SILTY CLAY		6	20	14
SANDY CLAY		20	26	6
CLAYEY GRAVEL		26	32	6
SILTY CLAY		32	40	8

TD = 40'

RECEIVED
JUN 18 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started MAY 24, 1993
Date completed MAY 24, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	40 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	2 lbs	SCH 40	0	40

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 0.020
From 20 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-18
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ ~~Cement~~ BENTONITE Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 18 feet to 40 feet

9. WATER LEVEL
Static water level 10.7 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RICHARD LEBLANC
Contractor
Address 4670 S. POLARIS AV.
Contractor
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1817
Signed
By driller performing actual drilling on site or contractor
Date 6-18-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627