WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41599
Permit No.
Basin 212

NOTICE OF INTENT NO. 10180

1. OWNER: DEPARTMENT OF AVIATION
MAILING ADDRESS: P.O. BOX 11005
AIRPORT STATION, LAS VEGAS, NV

ADDRESS AT WELL LOCATION: NW CORNER OF PARADISE & TROPICANA
LAS VEGAS, NV

2. LOCATION: SW ¼ SW ¼ Sec. 22 T. 21 N/S R. 61 E. CLARK County

PERMIT NO. MO-2278 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED: ☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE: ☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILTY SAND		0	5	5
CALICHE		5	15	10
GRAVELLY SAND		15	20	5
SILTY SAND		20	26	6
GRAVELLY SAND		26	30	4
SILTY CLAY		30	35	5
TD = 35'				

RECEIVED
JUN 18 1993
Div. of Water Resources
Branch Office Las Vegas, NV

Date started MAY 3, 1993
Date completed MAY 3, 1993

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches		0 Feet	35 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	.7 lbs	SCH 40	0	35

Perforations:
Type perforation: FACTORY SLOTTED
Size perforation: 0.020"
From 5 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-3/1-3' BENT
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 3 feet to 35 feet

9. WATER LEVEL
Static water level 17 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DON WILSON
Contractor
Address 4670 S. POLARIS AV.
Contractor
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589
Signed
By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627