WDH-6

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41103
Permit No.
Basin 31

NOTICE OF INTENT NO.

1. OWNER NEVADA GOLD MINING
MAILING ADDRESS P.O. BOX 1820
WINNEMUCCA NV 89445

ADDRESS AT WELL LOCATION
AMAX SLEEPER MINE

2. LOCATION SE ¼ NW ¼ Sec. 21 T 40 N/X R 35 E HUMBOLDT County

PERMIT NO. (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| I PUMPED 250 GAL OF BENTONITE DOWN THE 2" WELL UNTIL FULL. I THEN LET IT SETTLE AND TOPPED OFF THE BENTONITE. I THEN PUT 25 GAL OF 16#/GAL CEMENT GROUT ON TOP OF THE BENTONITE. CASING WAS SEALED AT SURFACE AND WAS NOT PULLED. CASING WAS SLOTTED FROM 60 FT DOWN SO IT WAS NOT RIPPED. | | | | |

Date started JUNE 22, 1993
Date completed JUEN 22, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 620 Feet Depth Cased 620 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 6-3/4 Inches | 0 Feet | 620 Feet | |
| Inches | Feet | Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 | | SCH 40 | 0 | 60 |
| | | | | |

Perforations:
Type perforation SLOT
Size perforation .125 24 SLOTS/FT
From 60 feet to 620 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1488

Signed (By driller performing actual drilling on site or contractor)
Date JUNE 22, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627