WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41607
Permit No.
Basin 3

NOTICE OF INTENT NO. 11473

1. OWNER Edward M. Smith
MAILING ADDRESS P.O. Box 1767
Jamestown, CA 95634

ADDRESS AT WELL LOCATION 3 miles South 140 on Dovey Town Road - off 140 Hi
Humboldt County, NV

2. LOCATION SW ¼ NW ¼ Sec. 13 T. 40 N/S R. 36 E. Humboldt County

PERMIT NO. mm-93 (Issued by Water Resources) | Parcel No. N/A | N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [X] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	20	
Sand + Gravel		20	40	
Clay		40	105	
Sand + Gravel		105	120	
Clay		120	123	
Sand + Gravel		123	140	

Date started June 28, 19 93
Date completed June 29, 19 93

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 7/8 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	+1	140

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 110 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 55
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 55 feet to 140 feet

9. WATER LEVEL
Static water level 22 feet below land surface
Artesian flow None G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson (Contractor)
Address 10760 Grass Valley Road (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1375
Signed [signature] (by driller performing actual drilling on site or contractor)
Date July 1st 1993

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627