WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41646
Permit No.
Basin 49

NOTICE OF INTENT NO. 11346

1. OWNER George F. & Volga Skivington
MAILING ADDRESS ELKO, NEVADA 89803
ADDRESS AT WELL LOCATION West Airport Road ELKO, NEVADA

2. LOCATION ¼ NW ¼ Sec. 20 T. 34 (N/S) R. 55 E. ELKO County
PERMIT NO. N/A (Issued by Water Resources) Parcel No. 30' South 50'W of N.E. corner of parcel (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top soil		0	8	8
clay/alluvium		8	45	37
caliche		45	60	15
alluvium/clay	X	60	75	15
alluvium w clay		75	200	125
gravel - sand	X	200	235	35
alluvium/gravel	X	235	255	20
		T.D.		

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
air lift	45		4 hrs

Date started 5/20/93, 19
Date completed 5/26/93, 19

8. WELL CONSTRUCTION
Depth Drilled 255 Feet Depth Cased 255 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	50 Feet
7 7/8 Inches		50 Feet	255 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.72	.188	0	195
6 5/8	≈ 12	.180	195	255

Perforations:
Type perforation milled slot
Size perforation 1/8"
From 195 feet to 255 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 65
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 195 feet to 255 feet

9. WATER LEVEL
Static water level 45 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gustin Corporation (Contractor)
Address P.O. Box 894 (Contractor)
ELKO, Nev 89803
Nevada contractor's license number issued by the State Contractor's Board 0022195
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1821
Signed Michael O. Gustin (By driller performing actual drilling on site or contractor)
Date 6-1-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627