PZ-90 5+6

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41663
Permit No.
Basin 4-601

NOTICE OF INTENT NO. 13903

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SE ¼ SE ¼ Sec. 19 T. 36 N/S X R. 50 E. EUREKA County
PERMIT NO. M-0278 Issued by Water Resources | N/A Parcel No. | N/A Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strat.	From	To	Thickness
ABANDONED ENTIRE DEPTH				
WITH NEAT CEMENT				
WELL CASING WAS SEALED AT THE SURFACE, SO IT				
WAS NOT PULLED. CASING WAS NOT RIPPED DUE				
TO SLOTTS ALREADY IN CASING AND DUE TO CHANGE				
ORDER #1038.				

'93 JUN -2 A11:28
RECEIVED
STATE ENGINEER'S OFFICE

Date started MAY 7, 19 93
Date completed MAY 7, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

JUN 17 AM 10:38
RECEIVED
STATE ENGINEER
'93

8. WELL CONSTRUCTION
Depth Drilled 495 Feet Depth Cased 475 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches	0 Feet	495 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1.0		.125	0	231
1.0		.125	0	475

Perforations:
Type perforation SLOT
Size perforation .125
From 191 feet to 231 feet
From 475 feet to 660 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 191, 475 feet to 231, 495 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1773

Signed Mark Watt (By driller performing actual drilling on site or contractor)
Date MAY 7, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627