

OFFICE USE ONLY	
Log No.	41660
Permit No.	
Basin.	4-61

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

### WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13902

1. OWNER BARRICK GOLDSTRIKE ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINE  
 MAILING ADDRESS P.O. BOX 29  
ELKO, NV 89801

2. LOCATION NW  $\frac{1}{4}$  NE  $\frac{1}{4}$  Sec. 30 T. 36 N. X R. 50 E. EUREKA County  
 PERMIT NO. M-0278 N/A Subdivision Name N/A  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ABANDONED ENTIRE DEPTH WITH NEAT CEMENT				
WELL CASING WAS SEALED AT THE SURFACE, SO IT WAS NOT PULLED. CASING WAS NOT RIPPED DUE TO SLOTS ALREADY IN CASING AND DUE TO CHANGE ORDER #1038.				

8. WELL CONSTRUCTION  
 Depth Drilled 345 Feet Depth Cased 345 Feet

HOLE DIAMETER (BIT SIZE)  
 From 6 Inches To 0 Feet 345 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1		.125	0	345

Perforations:  
 Type perforation SLOT  
 Size perforation .125  
 From 310 feet to 345 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 310 feet to 345 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started MAY 7 1993  
 Date completed MAY 7 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING Contractor  
 Address 2286 WEST 1500 SOUTH Contractor  
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number 0021976  
 issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1773

Signed Mark Warts  
 By driller performing actual drilling on site or contractor

Date MAY 7, 1993

93 JUN -2 AM 11:28  
 RECEIVED  
 STATE ENGINEERS OFFICE

93 JUN 17 AM 11:38  
 STATE ENGINEERS OFFICE