PZ-93-2

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41663
Permit No.
Basin 061

NOTICE OF INTENT NO. 16334

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SW ¼ NW ¼ Sec. 30 T 36 N/S R 50 E EUREKA County

PERMIT NO. M-0-441 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
PUMP CEMENT TO SURFACE FROM 318'.				
WELL CASING WAS SEALED AT THE SURFACE SO IT WAS NOT PULLED. CASING WAS NOT RIPPED DUE TO SLOTS ALREADY IN CASING AND DUE TO CHANGE ORDER #1038.				

'93 JUN 12 AM 11:16 STATE ENGINEER'S OFFICE

Date started JUNE 4, 1993
Date completed JUNE 4, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 430 Feet Depth Cased 318 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
5-1/2 Inches	0 Feet	430 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1-1/4	2	SCH 40	0	318

Perforations:
Type perforation SLOT
Size perforation .025
From 318 feet to 258 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 56
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 231 feet to 320 feet

9. WATER LEVEL
Static water level 209 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources the on-site driller 1410

Signed [signature] (By driller performing actual drilling on site or contractor)
Date JUNE 4, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627