

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16331

1. OWNER BARRICK GOLDSTRIKE ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINE  
 MAILING ADDRESS P.O. BOX 29  
ELKO, NV 89801

2. LOCATION SW NW  $\frac{1}{4}$  Sec. 30 T. 36 N X R. 50 E. EUREKA County  
 PERMIT NO. 55146 N/A  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
PUMP THICK MUD 80 VIS.		FROM		
BOTTOM OF HOLE 307' TO SURFACE,				
CEMENT FROM 50' TO SURFACE.				
WELL CASING WAS SEALED AT THE SURFACE, SO IT WAS NOT PULLED. CASING WAS NOT RIPPED DUE TO SLOTS ALREADY IN CASING AND DUE TO CHANGE ORDER #1038.				

8. WELL CONSTRUCTION  
 Depth Drilled 310 Feet Depth Cased 305 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>19</u> Inches	<u>0</u> Feet	<u>20</u> Feet
<u>13-1/8</u> Inches	<u>20</u> Feet	<u>310</u> Feet
..... Inches	..... Feet	..... Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>14</u>	<u>55</u>	<u>3/8</u>	<u>0</u>	<u>20</u>
<u>6-5/8</u>	<u>17</u>	<u>.25</u>	<u>0</u>	<u>305</u>

Perforations:  
 Type perforation SLOT  
 Size perforation 1/8"

From <u>140</u>	feet to	<u>300</u>	feet
From .....	feet to	.....	feet
From .....	feet to	.....	feet
From .....	feet to	.....	feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 150 feet to 310 feet

Date started MAY 17 1993  
 Date completed MAY 18 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 230 feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING Contractor  
 Address 2286 WEST 1500 SOUTH Contractor  
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number 0021976  
 issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410

Signed [Signature]  
 By driller performing actual drilling on site or contractor

Date MAY 20, 1993