NA-28

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41678
Permit No.
Basin 62

NOTICE OF INTENT NO. 16329

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SE ¼ NW ¼ Sec. 29 T. 37 N/X R. 49 E. EUREKA County

PERMIT NO. M/O-413A (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVEL		0	10	10
VOLCANICS		10	1105	1095

'93 JUN -6 P2:04
STATE ENGINEER

Date started MAY 23, 19 93
Date completed JUNE 3, 19 93

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100		

8. WELL CONSTRUCTION #1:1099
Depth Drilled 1105 Feet Depth Cased #2: 799 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6-1/2	Inches	0	Feet	5	Feet
5-3/4	Inches	5	Feet	1105	Feet
	Inches		Feet		Feet

CASING SCHEDULE

	Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	6	17	.25	0	5
#1	1¼	2	SCH 40	0	1099
#2	1¼	2	SCH 40	0	799

Perforations:
Type perforation DRILLED
Size perforation 1/8"
From #1 899 feet to 1099 feet
From #2 739 feet to 799 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 56
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From #1: 879-1105 feet to #2: 718-810 feet

9. WATER LEVEL
Static water level 492 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 70 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the ~~on-site~~ driller 1410
Signed (By driller performing actual drilling on site or contractor)
Date JUNE 3, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627