WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41694
Permit No.
Basin 66

NOTICE OF INTENT NO.

1. OWNER GOLD FIELDS OPER. CO. -CHIMNEY CREEK
MAILING ADDRESS P. O. BOX 69
GOLCONDA, NV 89414

ADDRESS AT WELL LOCATION 35 MILES NE OF GOLCONDA, NV

2. LOCATION SW ¼ SW ¼ Sec. 20 T. 39N N/S R. 43E E. HUMBOLDT County
PERMIT NO. M/O-473-A Hydro # (Issued by Water Resources) 5 (Parcel No.) Exploration Hole # SEE-805 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	435	435
Siltstone		435	470	35
Altered Basalt		470	495	25
Siltstone		495	515	20
Altered Basalt		515	530	15
Siltstone		530	565	35
Altered Basalt		565	600	35

'93 MAY 26 A11:52
RECEIVED
STATE ENGINEERS OFFICE

Date started May 3, 19 93
Date completed May 4, 19 93

7. WELL TEST DATA – NONE –
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 600 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
5¼ Inches		0 Feet	600 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1" PVC		Schedule 40	0	400

Perforations:
Type perforation Factory
Size perforation
From 360 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 340' to surface
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 340 feet to 578 feet

9. WATER LEVEL
Static water level 207 feet below land surface
Artesian flow NONE G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was completed under my supervision and the report is true to the best of my knowledge.

Name (Contractor)
Address (Contractor)

Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1755

Signed David J. Altmann
(By driller performing actual drilling on site or contractor)
Date 8/19/93

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627