

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 4167  
Permit No. 69  
Basin. 69

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21491

1. OWNER Jim Delaney ADDRESS AT WELL LOCATION No physical address available at this time  
MAILING ADDRESS 416 W. 2nd St. Winnemucca, NV 89445  
2. LOCATION NE 1/4 NE 1/4 Sec. 9 T. 37 N/S R. 38 E Humboldt County  
PERMIT NO. "NA" Issued by Water Resources Parcel No. "NA" Subdivision Name "NA"

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	8	
Clay		8	12	
Black rock w/clay		12	25	
Black Rock "Cemented"		25	60	
Cemented Gravel-Black		60	120	
Rock w/s clay stringer		120	133	
Rock - Black		133	180	
Black Rock w/s clay		180	200	
Volcanic Hard Rock Black		200	228	

'93 JUN 15 AM 9:52

8. WELL CONSTRUCTION  
Depth Drilled 228 Feet Depth Cased 228 Feet  
HOLE DIAMETER (BIT SIZE)  
From 0 To 228  
10" Inches 0 Feet 228 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>228</u>

Perforations:  
Type perforation Torch 1/8 x 3"  
Size perforation \_\_\_\_\_  
From 170 feet to 228 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50 FT.  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 50 feet to 228 feet

9. WATER LEVEL  
Static water level 70 feet below land surface  
Artesian flow None G.P.M. NONE P.S.I.  
Water temperature Cold °F Quality Good

Date started June 4, 1993  
Date completed June 10, 1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>20</u>	<u>2.00</u>	<u>3 Hrs.</u>	

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Dave McIninch Contractor  
Address 8005 McIninch Rd. Winnemucca, NV 89445 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 5437  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 730  
Signed Harold Lee Mowitz  
By driller performing actual drilling on site or contractor  
Date June 11, 1993