WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41698
Permit No.
Basin 69

NOTICE OF INTENT NO. 22397

1. OWNER Jim Delaney
MAILING ADDRESS 416 W. 2nd. Wmca., Nv. 89445
ADDRESS AT WELL LOCATION 3560 Mark Lane

2. LOCATION SW ¼ SW ¼ Sec. 10 T. 37N N/S R. 38E E. Humboldt County
PERMIT NO. (Issued by Water Resources) 6-481-24 (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
[*] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[*] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[*] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil Sandy Brown		0	2	2
Clay Brown		2	6	4
Gravel Brown		6	24	18
Gravely Clay Brown		24	32	8
Cemented Gravel Brown		32	68	36
Gravely Clay Brown		68	99	31
Sand + Gravel Brown	21	99	120	

'93 MAY 26 AM 10:44 STATE ENGINEER

Date started 4-23-, 1993
Date completed 4-30-, 1993

7. WELL TEST DATA
TEST METHOD: [*] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	5	3

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
6 Inches		50 Feet	120 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	14	.188	0	120

Perforations:
Type perforation Torch
Size perforation 1/8" by 5"
From 95 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [*] Yes [ ] No
Depth of Seal 50'
Placement Method: [*] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [*] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [*] No
From feet to feet

9. WATER LEVEL
Static water level 36 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 54 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T + R DRILLING (Contractor)
Address P.O. Box 1982 Wmca., Nv. 89446 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 017721
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1190
Signed Thomas [signature] (By driller performing actual drilling on site or contractor)
Date 4-30-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627