WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

REVISED

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41706
Permit No.
Basin

NOTICE OF INTENT NO. 18736

1. OWNER Brad Santucci
MAILING ADDRESS 304040 Dry Creek Road
Prineville, OR 97754

ADDRESS AT WELL LOCATION
6860 West Rose Creek Road
Winnemucca, NV

2. LOCATION NE ¼ NW ¼ Sec. 16 T. 35 N/S R. 37 E. Humboldt County

PERMIT NO. NA (Issued by Water Resources) | NA (Parcel No.) | NA (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ABANDON EXISTING WELL				
Total depth 125'				
Static 48'				
Casing 10 3/4 OD				
Positioned rig. Attempted to pull casing, was unsuccesful. Perforate casing from 50' to 125' with air operated perforater. Run tremie pipe to 125' and pump 20 sacks of bentonite mixed in 1000 gallons of water, to the surface. Bentonite set up to 45'. Mixed 20 more sacks and pumped to surface. Bentonite did not settle. Install plug at 50' and pump 27 bags of neat cement to the surface.				

'93 JUN 15 A9:52 STATE ENGINEER

Date started May 15, 19 93
Date completed May 16, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 125 Feet Depth Cased 125 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address P.O. Box 590 (Contractor)
Winnemucca, NV 89446
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1448
Signed Jane D. Choate (By driller performing actual drilling on site or contractor)
Date 6-14-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627