WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41712
Permit No.
Basin 87

NOTICE OF INTENT NO. 15263

1. OWNER Reno Cannon International Airport
MAILING ADDRESS 2001 East Plumb Lane Reno NV
ADDRESS AT WELL LOCATION Reno Cannon International Airport Reno NV Site 1 FTA

2. LOCATION SW ¼ SW ¼ Sec. 20 T. 19 N/S R. 20 E. Washoe County
PERMIT NO. MO 594 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. B-23 LITHOLOGIC LOG MW-1

Material	Water Strata	From	To	Thickness
The well was found to be in good condition. The bottom was perforated then we pressure grouted inside the casing while pulling the casing out of the ground. We used approximately four bags of Type I-II portland cement per hole at a ratio of 6 gallons of water per bag. We let the hole set for about one hour then topped off the hole with more of the same type of mix.				
P+A of log # 41763				

Date started 4/6, 1993
Date completed 4/6, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	N/A	

8. WELL CONSTRUCTION
Depth Drilled 21.5 Feet Depth Cased 21.5 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	21.5 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	Sch. 40	0	21.5

Perforations:
Type perforation Factory Slot
Size perforation .010 inches
From feet to feet
From 4 feet to 21.5 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 3'
Placement Method: ☒ Pumped ~~☒ Poured~~

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 3 feet to 21.5 feet

9. WATER LEVEL
Static water level 4.5 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Anderson Drilling (Contractor)
Address 1635 Belford RD. Reno NV 89509 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] By driller performing actual drilling on site or contractor
Date 5/19/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627