

OFFICE USE ONLY  
 Log No. 49716  
 Permit No. \_\_\_\_\_  
 Basin A7

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15275

1. OWNER Bald Mountain Mine ADDRESS AT WELL LOCATION Bald Mtn Mine  
 MAILING ADDRESS PO Box 2706 Elko NV 89801

2. LOCATION SE 1/4 NE 1/4 Sec 24 T 24 R 56 E White Pine County  
 PERMIT NO. MD 667 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE Cepr  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Cepr

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravelly Sand	No	0	50	50
Gravelly Clay	No	50	57	7
Silty Clay	No	57	63	6
Gravelly Sand	No	63	120	57
Groundwater is at approximately 500 feet				

8. WELL CONSTRUCTION  
 Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 0 Feet 120 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PX</u>	<u>sch. 40</u>	<u>0</u>	<u>120</u>

Perforations:  
 Type perforation Factory slot  
 Size perforation .020 Inch

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 10 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 8  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 8 feet to 120 feet

9. WATER LEVEL  
 Static water level N/A feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 5/10 1993  
 Date completed 5/11 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<u>N/A</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Anderson Drilling  
 Address 1635 Belvedere RD. RENO NV. 89509

Nevada contractor's license number issued by the State Contractor's Board 34525  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028

Signed Paul Anderson  
 By driller performing actual drilling on site or contractor  
 Date 5/11/93