WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41740
Permit No.
Basin 84

NOTICE OF INTENT NO. 21123

1. OWNER Reno-Sparks Indian Colony
MAILING ADDRESS
ADDRESS AT WELL LOCATION Hungry Valley

2. LOCATION NE ¼ NW ¼ Sec. 4 T. 21 N/S R. 20 E. W Ashoe County
PERMIT NO. 57930 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	22	22
White D.G.		22	28	6
Shale with				
Diatomaceous		28	96	68
Green Shaly				
Clay with shallow				
hard streaks		96	445	
Same with Grey				
Chips and hard				
streaks		445	489	
Multi Colored				
Sand with green				
Shaly Clay		489	695	

Date started 3-15, 1993
Date completed 6-22, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
150	340'	24 HRS

8. WELL CONSTRUCTION
Depth Drilled 695 Feet Depth Cased 680 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
14 Inches	0 Feet	695 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4	32	.250	+3	460
6 5/8	17	.250	460	680

Perforations:
Type perforation Houston Screen SS
Size perforation .090
From 460 feet to 500 feet
From 560 feet to 600 feet
From 640 feet to 680 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 65
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 65 feet to 495 feet

9. WATER LEVEL
Static water level 25-3 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco (Contractor)
Address Box 888 (Contractor)
Fallon
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
Signed (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627