

OFFICE USE ONLY  
 Log No. 1743  
 Permit No. 341  
 Basin 341  
 NOTICE OF INVENT NO. 21822

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER RICK WELLS ADDRESS AT WELL LOCATION 100 Quivera Lane  
 MAILING ADDRESS 40 Date Palm Drive Sparks, NV 89436  
 2. LOCATION SE 1/4 SW 1/4 Sec 9 T 21N N/S R 21 E Washoe County  
 PERMIT NO. 076-300-16 Spanish Springs Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1/2	1/2
Brown clay w/DG mixed		1/2	6	5 1/2
White clay		6	12	6
Brown clay w/DG mixed		12	38	26
Green volcanic rock		38	77	39
Black volcanic rock		77	88	11
Red volcanic rock		88	91	3
Brown volcanic rock		91	118	27
Black volcanic rock		118	210	12
Black sandy clay		210	259	49
Gray sandy clay		259	299	40
Soft zone(app 3 GPM)	X	299	334	35
Gray volcanic rock		334	348	14
Fracture	X	348	350	2
Gray volcanic rock		350	377	27
Fracture	X	377	379	2
Gray volcanic rock		379	400	21

8. WELL CONSTRUCTION  
 Depth Drilled 400 Feet Depth Cased 400 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
6 5/8 Inches 50 Feet 400 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	400

Perforations: factory sawed slot  
 Type perforation  
 Size perforation 3/32 x 3 x 5 around  
 From 295 feet to 315 feet  
 From 335 feet to 355 feet  
 From 375 feet to 395 feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 400 feet

9. WATER LEVEL  
 Static water level 150 feet below land surface  
 Artesian flow 20 G.P.M. P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc. Contractor  
 Address P.O. Box 12370 Contractor  
Reno, NV 89510  
 Nevada contractor's license number 22549  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 923  
 Division of Water Resources, the on-site driller  
 Signed Jerry C. Helmer  
 By driller performing actual drilling on site or contractor  
 Date June 25, 1993

Date started 6-21-93, 19\_\_\_\_  
 Date completed 6-23-93, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			