WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41749
Permit No.
Basin 84

NOTICE OF INTENT NO. 20567

1. OWNER JERRY WILLIAMS
MAILING ADDRESS P.O. Box 21048, Reno, NV 89515
ADDRESS AT WELL LOCATION 6205 Range Land Road, Reno, NV 89510

2. LOCATION NW ¼ NW ¼ Sec 36 T 23N N/S R 20 E Washoe County
PERMIT NO. (Issued by Water Resources) 076-110-17 (Parcel No.) Palomino Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [X] Other & MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Sandy brown clay		1	3	2
Soft fine sand		3	21	18
Brown sand & gravels with clay streaks		21	69	48
Brown silty clay		69	76	8
Brown sandy clay		76	111	35
brown fine to med. sand w/fine silty clays		111	136	25
Brown clay		136	154	18
BRown sand	X	154	165	9
Brown silty clay		165	173	8
Soft zone	X	173	183	10
BRown clay		183	190	7
Soft zone	X	190	198	8
Brown sandy clay		198	210	12

'93 MAY 26 A11:50
STATE ENGINEER'S OFFICE

Date started 5-13-93, 19
Date completed 5-18-93, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 210 Feet Depth Cased 210 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10	0	100
9 7/8	100	210

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	210

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 163 feet to 203 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 210 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow 60 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date May 20, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627