

OFFICE USE ONLY
Log No. 41752
Permit No. 87
Basin 87

087 N18 E19 01 CCC
PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 8600 Lake Side

1. OWNER Theodore Huff ADDRESS AT WELL LOCATION 8600 Lake Side Reno Nev
MAILING ADDRESS 1835 Peacock Rd Reno Nev
2. LOCATION N18 E19 01 CCC T. 18 S. R. 20 E Washoe County
PERMIT NO. 40-631-01 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>De com posed granite</u>		<u>0</u>	<u>50</u>	<u>50</u>
<u>Bol-lders</u>				
<u>sand & clay</u>		<u>50</u>	<u>100</u>	<u>50</u>
<u>clay</u>		<u>100</u>	<u>120</u>	<u>20</u>
<u>gravel</u>		<u>120</u>	<u>167</u>	<u>47</u>

8. WELL CONSTRUCTION
Depth Drilled 167 Feet Depth Cased 167 Feet

HOLE DIAMETER (BIT SIZE)
12 1/4 Inches From 0 Feet To 167 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8"</u>	<u>16.94</u>	<u>1.88</u>	<u>0</u>	<u>167</u>

Perforations:
Type perforation MULL SLOT
Size perforation Standard
From 127 feet to 167 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type:
Depth of Seal 100' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 100 feet to 167 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow 20 G.P.M. 10 P.S.I.
Water temperature Cold F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling Contractor
Address 2290 Thirteen Drive Reno Nevada 89509 Contractor
Nevada contractor's license number issued by the State Contractor's Board 14170
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1476
Signed Mike Foster
By driller performing actual drilling on site or contractor
Date 5-9-93

Date started 4-27 1993
Date completed 5-1 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50-75</u>		<u>4 hrs</u>