WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41753
Permit No.
Basin 87

NOTICE OF INTENT NO. 21533

1. OWNER Roger Whybrew
MAILING ADDRESS P.O. Box 40053
Reno, NV 89504

ADDRESS AT WELL LOCATION
2150 Whites Creek Lane
Reno, NV 89511

2. LOCATION NE ¼ NE ¼ Sec 30 T 18N N/S R 20 E Washoe County

PERMIT NO. (Issued by Water Resources) | 49-371-04 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tried to deepen existing well but had metal obstructions and was unable to deepen this well. The well was dry and we perforated the well from bottom to approximately 10' from surface using a Mills Knife perforator. We then filled the well from bottom to top to seal the well. We then cut the top 2' of exposed casing down to below grade and covered the well location with surrounding dirt. We then moved over approximately 6' to the NE and drilled a new well to 340'. This existing well was said to have been drilled to 265' and it took approximately 3½ yards cement to abandon. This was a 6 5/8" well originally.				

'93 JUN 9 AM 8:39
STATE ENGINEER

Date started 5-25-'93, 19
Date completed 5-25-'93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level none feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MacKay Pump & Geothermal, Inc. (Contractor)
Address 1600 Mt. Rose Hwy. Reno, NV 89511 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on site or contractor)
Date 5-28-'93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627