

OFFICE USE ONLY
 Log No. 41763
 Permit No. OT
 Basin OT

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15264

1. OWNER Pero Capron International Project ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 2001 East Plumb Lane Reno NV
 2. LOCATION SW 1/4 SW 20 T. 19 N. R. 20 E. Washoe County
 PERMIT NO. MW 594 P Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Logan

6. Apcon B-23 LITHOLOGIC LOG MW-1

Material	Water Strata	From	To	Thick-ness
<u>Brown Sand</u>	<u>No</u>	<u>0</u>	<u>5'</u>	<u>5'</u>
<u>Sandy Gravel</u>	<u>No</u>	<u>5'</u>	<u>7.5'</u>	<u>2.5'</u>
<u>Clayey Sand</u>	<u>Yes</u>	<u>7.5'</u>	<u>20.0'</u>	<u>12.5'</u>

93 JUL -2 11:22
 STATION 574112

see log # 41712 for P&A

8. WELL CONSTRUCTION
 Depth Drilled 20 Feet Depth Cased 20 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 20 Feet
 From 0 Feet To 20 Feet
 From 0 Feet To 20 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>Sh. 40</u>	<u>0</u>	<u>20</u>

Perforations:
 Type perforation Factory Slot
 Size perforation 1/20 Inches
 From 8 feet to 20 feet
 From 8 feet to 20 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 4
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 4 feet to 20 feet

9. WATER LEVEL
 Static water level 9.3 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature Call °F Quality N/A

Date started 4/9 1993
 Date completed 4/9 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
		<u>N/A</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Andrew Dilling Contractor
 Address 1635 Belknap Rd, Reno NV 89509
 Nevada contractor's license number 34325 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1028
 Signed Andrew Dilling
 By driller performing actual drilling on site or contractor
 Date 5/19/93