WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41771
Permit No.
Basin 89

NOTICE OF INTENT NO. 17713

1. OWNER Tom Pogan c/o
MAILING ADDRESS 215 Bruce way
New Washo City

ADDRESS AT WELL LOCATION 215 Bruce ~~Bruce~~ way New Washo.

2. LOCATION SW ¼ SW ¼ Sec. 30 T. 17 N/S R. 20 E. Washo County
PERMIT NO. Issued by Water Resources
50-291-06 Parcel No.
Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soft Sand		0	6	6
Firm Sandstone		6	45	39
Brown Sandy Clay		45	50	5
Course DG. Sands	X	50	65	15
DG Sands/w Gray Clay Seams		65	105	40
Firm Granite		105	190	85
Broken hard Granite		190	205	15
Gray Silty Clay		205	215	10
Broken D.G. Water Zone	XXX	215	230	15

Date started 5/22, 1993
Date completed 5/25, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	50'	5

8. WELL CONSTRUCTION
Depth Drilled 230' Feet Depth Cased 230' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11¼ Inches	0 Feet	55 Feet
10¾ Inches	55 Feet	230 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.07	.188	0	230

Perforations:
Type perforation Mill Slot
Size perforation 3½ X 3/32
From feet to feet
From 100 feet to 120 feet
From 210 feet to 230 feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☑ Poured

Seal Type:
☑ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 230 feet

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow G.P.M. 30 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & H PUMP CO Contractor
Address 5551 Hwy 50 East Carson City, Nevada 89 883-0459 Contractor 885-1889

Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674

Signed Joe Butts
By driller performing actual drilling on site or contractor
Date 5/25/93

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627