

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17719

1. OWNER Central Enterprises ADDRESS AT WELL LOCATION 185 Cottonail
 MAILING ADDRESS 3995 River Haven New Washo City
Dr. Reno NV. 89509
 2. LOCATION NE 1/4 NW 1/4 Sec. 31 T. 17 N. R. 20 E Washo County
 PERMIT NO. 50-366-02 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------------|--------------|------------|------------|------------|
| <u>Sandstone</u> | | <u>0</u> | <u>140</u> | <u>140</u> |
| <u>Hard Fractured</u> | | | | |
| <u>Granite</u> | <u>xx</u> | <u>140</u> | <u>265</u> | <u>125</u> |

8. WELL CONSTRUCTION
 Depth Drilled 265 Feet Depth Cased 265 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 1/2 Inches 0 Feet 55 Feet
9 7/8 Inches 55 Feet 265 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 3/8</u> | <u>12.07</u> | <u>.188</u> | <u>0</u> | <u>265</u> |

Perforations:
 Type perforation Mill slot
 Size perforation 3/32 x 2 1/2
 From _____ feet to _____ feet
 From 245 feet to 265 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 55
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 55 feet to 265 feet

9. WATER LEVEL
 Static water level 140 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started 6-9 1993
 Date completed 6-11 1993

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|----------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>7</u> | <u>85</u> | <u>4</u> |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
A & H PUMP CO
 Name 5551 Hwy. 50 East
 Address Carson City, Nevada 897
883-0459 883-40
885-1889
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1472
 Signed Clinton R. Bullis
 By driller performing actual drilling on site or contractor
 Date 6-14-93