

OFFICE USE ONLY

Log No. 4774
 Permit No. _____
 Basin 89

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 9913

1. OWNER Dr. J. S. E. (CAVE) ADDRESS AT WELL LOCATION Lot 50
 MAILING ADDRESS 1322 Block Dr. E. Camorella, New Washo
Glenbrook Star Route 8944 City Washo
 2. LOCATION SW 1/4 SW 1/4 Sec. 32 T. 17 N. R. 20 E County Washo
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. 050-413-50 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0'	25'	25'
Brow Sandy Clay		25'	40'	15'
DC. Sands		40'	90'	50'
Hard Broken Granite		90'	155'	65'
Hard blue Granite		155'	160'	5'
Hard broken Granite water zone		160'	185'	25'
Hard Blue Granite		185'	200'	15'

'93 MAY 21 AMO 55
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 200' Feet Depth Cased 200' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>11 1/2"</u>	0'	60'
<u>10"</u>	60'	200'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13.03</u>	<u>.188</u>	<u>0'</u>	<u>200'</u>

Perforations:
 Type perforation 3/2 x 3/32
 Size perforation _____
 From 180' feet to 200' feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 55' Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 45' feet below land surface
 Artesian flow _____ G.P.M. 121 P.S.I.
 Water temperature Cold °F Quality Good

Date started 5/12/93
 Date completed 5/17/93

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>12</u>	<u>85'</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & H PUMP CO.
 Address 5551 Hwy 50 East #3 Carson City, Nevada 89701
883-0459 - 883-402
885-1889
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
 Signed Joe Bulth
 By driller performing actual drilling on site or contractor
 Date 5/14/93