

OFFICE USE ONLY  
 Log No. 47778  
 Permit No. 91  
 Basin. 91

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21796

1. OWNER Greg Reddicks High Sierra Const ADDRESS AT WELL LOCATION 950 Buckbrush  
 MAILING ADDRESS 42 Sun Cr  
Reno, Nv 89509

2. LOCATION SE 1/4 NW 1/4 Sec. 17 T. 19 N/S R. 18 E Washoe County  
 PERMIT NO. 038-074-29 - Verdi Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	1	1
Dark Brown clay		1	8	7
Cobbles boulders		8	15	7
Cobbles boulders & brown clay		15	60	45
Volcanic rock & brown clay stone		60	65	5
Hard boulders		65	70	5
Volcanic rock brown Claystone & cobbles & boulders		70	162	92
Green clay stone		162	193	31
Truckee formation		193	235	42
Mixture volcanic rock & claystone		235	279	44
T.D. 279 ft				

8. WELL CONSTRUCTION  
 Depth Drilled 279 Feet Depth Cased 279 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 59 Feet  
8 1/2 Inches 59 Feet 279 Feet  
 .....Inches.....Feet.....Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+ 1</u>	<u>279</u>

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 239 feet to 259 feet  
 From ..... feet to ..... feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 50 feet to 279 feet

9. WATER LEVEL  
 Static water level 140 feet below land surface  
 Artesian flow ..... G.P.M. .... P.S.I.  
 Water temperature cold °F Quality .....

Date started 3/31/93, 19.....  
 Date completed 4/1/93, 19.....

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>2</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc  
 Contractor  
 Address 625 Spice Islands Dr Suite L  
 Contractor  
Sparks, Nv 89431

Nevada contractor's license number 15291  
 issued by the State Contractor's Board

Nevada driller's license number issued by the 1804  
 Division of Water Resources, the on-site driller

Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor  
 Date 4/2/93