

OFFICE USE ONLY
 Log No. 4780
 Permit No. 923
 Basin 923

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21407

1. OWNER RAY GRIMM/LEMMON VALLEY MOBILE VILLAGE ADDRESS AT WELL LOCATION 11 Tuck
 MAILING ADDRESS 2805 Kietzke Lane Reno, NV 89502 Reno, NV 89506
 2. LOCATION NE 1/4 NW 1/4 Sec. 4 T 20N N/S R 19 E Washoe County
 PERMIT NO. 086-416-23 Lemmon Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL ABANDONMENT:				
Static Water level		58 feet		
Total Depth		119 feet		
Casing could not be pulled.				
Casing perforated with Holt down hole perforator from 0 to 115 feet.				
Cut casing below ground. Install trimie line, mix and pump cement slury to fill casing.				
Finish at grade.				
Materilas used:				
29 sacks of Portland Cement Type II				
2 sacks Bentonite Powder 2%				
Location:				
Well in SE corner, in well yard.				
4 feet in from E fence				
21 feet in from S fence.				

8. WELL CONSTRUCTION

Depth Drilled.....Feet Depth Cased.....Feet

HOLE DIAMETER (BIT SIZE)

From To

.....Inches.....Feet.....Feet

.....Inches.....Feet.....Feet

.....Inches.....Feet.....Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:

Type perforation.....

Size perforation.....

From.....feet to.....feet

From.....feet to.....feet

From.....feet to.....feet

From.....feet to.....feet

From.....feet to.....feet

Surface Seal: Yes No Seal Type:

Depth of Seal..... Neat Cement

Placement Method: Pumped Cement Grout

Poured Concrete Grout

Gravel Packed: Yes No

From.....feet to.....feet

9. WATER LEVEL

Static water level.....58.....feet below land surface

Artesian flow.....G.P.M.....P.S.I.

Water temperature.....°F Quality.....

Date started.....5-13-93....., 19.....

Date completed.....5-14-93....., 19.....

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc. Contractor

Address P.O. Box 12370 Contractor

Reno, NV 89510

Nevada contractor's license number issued by the State Contractor's Board. 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 908

Signed [Signature] By driller performing actual drilling on site or contractor

Date May 18, 1993