WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41783
Permit No.
Basin 92B

NOTICE OF INTENT NO. 23363

1. OWNER CHARLES BRICE
MAILING ADDRESS P.O. Box 20424
Sparks, NV 89433

ADDRESS AT WELL LOCATION 785 Winchester
Reno, NV 89506

2. LOCATION SE ¼ SE ¼ Sec. 10 T. 20N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 088-125-13 (Parcel No.) Golden Valley (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown sandy clay		0	9	9
Brown Decomposed Granite		9	35	26
Brown DG w/hard streaks		35	60	25
Gray granite		60	77	17
Weathered granite	X	77	91	14
Fractured granite	X	91	106	15
Weathered granite	X	106	113	7
WEathered granite with hard streaks		113	128	15
Gray granite		128	140	12
Weathered granite	X	140	161	21
Granite fracture at		161		
" " "	X	168		
" " "	X	173		
Weathered granite	X	173	180	7

Date started 5-6-93, 19
Date completed 5-7-93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8 5/8	Inches	50	Feet	180	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	180

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 140 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level 42.2 feet below land surface
Artesian flow 50+ G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed (By driller performing actual drilling on site or contractor)
Date May 10, 1993

RECEIVED MAY 14 AM 10:58 1993 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (11)-677