WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. [redacted]
Permit No. [redacted]
Basin 93

NOTICE OF INTENT NO. 22498

1. OWNER Kirt Dollerhide
MAILING ADDRESS 2350 Antelope Valley Rd Reno NV 89503
ADDRESS AT WELL LOCATION 2350 Antelope Valley Rd.

2. LOCATION NW ¼ SE ¼ Sec. 14 T. 22 N/S R. 19 E. W G/S/H.B. County
PERMIT NO. N/A Issued by Water Resources
79-CRB-67 70 Parcel No.
Redrock Estates #1 Parcel 3.05 Subdivision Name
Pcs-4

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☑ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Decomposed granite		0	60	60
Clay		60	64	4
Hard granite		64	140	76'
Hard granite with cracks and crevis.	✓	140	150	10'

Date started 4-19, 1993
Date completed 4-23, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air Developed For 1 Hour Produced 35 Gallons a min		

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 0-150 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	50	Feet
8"	Inches	60	Feet	150	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	3/16	+1	150

Perforations:
Type perforation air perf
Size perforation
From 130 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50 Feet
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 80 feet to 150 feet

9. WATER LEVEL
Static water level 130 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LEACH Drilling Contractor
Address PO Box 599 Silver Springs NV 89429 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0031891
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 790-T2
Signed [signature] By driller performing actual drilling on site or contractor
Date 5-17-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627

93 MAY 19 AM 1:32 STATE ENGINEER'S OFFICE