

OFFICE USE ONLY  
 Log No. 41796  
 Permit No. 101  
 Basin 101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 18117

1. OWNER N. D. E. P. ADDRESS AT WELL LOCATION 894 Main Street  
 MAILING ADDRESS 123 West Nye Lane Fallon, NV 89406  
Carson City, NV  
 2. LOCATION NW 1/4 SW 1/4 Sec 31 T 18 N R 28 E Churchill County  
 PERMIT NO. MO 639 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Other

6. LITHOLOGIC LOG B-11 MW-5

| Material                               | Water Strata | From      | To        | Thick-ness |
|--|--------------|-----------|-----------|------------|
| <u>Ben Silty Sand</u>                  | <u>No</u>    | <u>0</u>  | <u>4</u>  | <u>4</u>   |
| <u>Ben Silty Clay</u>                  | <u>No</u>    | <u>4</u>  | <u>5</u>  | <u>1</u>   |
| <u>Ben Sand</u>                        | <u>No</u>    | <u>5</u>  | <u>6</u>  | <u>1</u>   |
| <u>Dark Org. Clayey Sand w/ gravel</u> | <u>Yes</u>   | <u>6</u>  | <u>14</u> | <u>8</u>   |
| <u>Grey Sand</u>                       | <u>Yes</u>   | <u>14</u> | <u>20</u> | <u>6</u>   |

8. WELL CONSTRUCTION  
 Depth Drilled 20 Feet Depth Cased 20 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 0 Feet 20 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>2</u>           | <u>PVC</u>          | <u>Sch. 40</u>          | <u>0</u>    | <u>20</u> |

Perforations:  
 Type perforation Factory Slot  
 Size perforation 0.010 Inches  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 5 feet to 20 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 4  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 4 feet to 20 feet

9. WATER LEVEL  
 Static water level 10.0 feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature Cell °F Quality N/A

Date started 3 12, 19\_\_\_\_  
 Date completed 3 12, 19\_\_\_\_

7. WELL TEST DATA

| TEST METHOD:  | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift |        |                               |              |
|   |        | <u>N/A</u>                    |              |

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Anderson Drilling  
 Address 1635 Belford Rd.  
RENO, NV 89509  
 Nevada contractor's license number 34525  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1028  
 Division of Water Resources, the on-site driller  
 Signed Paul Anderson  
 By driller performing actual drilling on site or contractor  
 Date 5/19/83