

OFFICE USE ONLY  
 Log No. 41804  
 Permit No. \_\_\_\_\_  
 Basin 101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18113

1. OWNER Northside Elementary School ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 340 Venturacci Lane Fallen NV \_\_\_\_\_  
 2. LOCATION NE 1/4 SE 1/4 Sec. 25 T. 19 N. R. 28 E. Churchill County  
 PERMIT NO. 100646 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Plug

6. LITHOLOGIC LOG MW-3

Material	Water Strata	From	To	Thickness
<u>Ben Silty Clay</u>	<u>No</u>	<u>0</u>	<u>5</u>	<u>5</u>
<u>Ben. Sand</u>	<u>Yes</u>	<u>5</u>	<u>10</u>	<u>5</u>
<u>Ben. Sand</u>	<u>Yes</u>	<u>10</u>	<u>15</u>	<u>5</u>

8. WELL CONSTRUCTION  
 Depth Drilled 15 Feet Depth Cased 15 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 15 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>	<u>PVC</u>	<u>Sch. 40</u>	<u>0</u>	<u>15</u>

 Perforations:  
 Type perforation Factory Slot  
 Size perforation 1020 Inches  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 4 feet to 15 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 3  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 3 feet to 15 feet  
 9. WATER LEVEL  
 Static water level N/A feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature Cold °F Quality N/A

Date started 3/23, 1973  
 Date completed 3/23, 1973

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		<u>N/A</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Andrew Drilling  
 Address 1635 Belford Rd. Reno NV 89509  
 Nevada contractor's license number issued by the State Contractor's Board 34525  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 5/19/93