



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24056

1. OWNER Hammond Homes & Construction ADDRESS AT WELL LOCATION 2050 Hammond Drive
 MAILING ADDRESS 1780 Lattin Road Fallon, NV 89406
 2. LOCATION SE 1/4 SE 1/4 Sec 35 T 19 N 3 R 28 E Churchill County
 PERMIT NO. 08-831-08 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	22	22
Brown Clay		22	26	4
Brown COarse Snad		26	31	5
Fine Brown Sand		31	35	4
Fine Green Sand		35	37	2
Black & Green COarse Sand		37	43	6
Fine Green Sand		43	48	5
Black & Green COarse Sand		48	56	8
Fine Black Sand		56	64	8
Fine Gray Sand		64	76	12
Black & Green COarse Sand		76	84	8
Fine Gray Sand		84	86	2
Black & Green COarse Sand		86	94	8
Brown COarse Sand		94	101	7
Brown Clay		101	103	2
Brown COarse Sand	X	103	115	12

8. WELL CONSTRUCTION
 Depth Drilled 115 Feet Depth Cased 115 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 115 Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	115

 Perforations:
 Type perforation Mill Cut
 Size perforation 1/8"
 From 109 feet to 112 feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 100 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 100 feet to 115 feet

Date started July 24, 1993
 Date completed July 24, 1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL
 Static water level 11' 7" feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling, Inc. Contractor
 Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265
 Nevada contractor's license number 29064 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
 Signed Doug Parsons By driller performing actual drilling on site or contractor
 Date July 1 1993

JUL -6 P1 55
 RECEIVED
 STATE ENGINEERS OFFICE