WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41815
Permit No.
Basin 102

NOTICE OF INTENT NO. 23985

1. OWNER American Property Services, Inc.
MAILING ADDRESS 1317 Jones St.
Reno, Nevada 89503

ADDRESS AT WELL LOCATION 2650 E. Fourth St.
Silver Springs Nevada 89429

2. LOCATION NW ¼ NW ¼ Sec. 21 T. 17 N/S R. 25 E. Lyon County
PERMIT NO. — Issued by Water Resources | 17-166-03 Parcel No. | Putnam #2 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Fine sand | | 0 | 25 | 25 |
| Fine sand + Brown clay | | 25 | 40 | 15 |
| Gray clay | | 40 | 45 | 5 |
| Fine To coarse sand + Brown clay | | 45 | 75 | 30 |
| coarse sand + some Brown clay | X | 75 | 150 | 75 |

RECEIVED MAY 21 '93 A10:39 STATE ENGINEERS OFFICE

Date started 5-10, 1993
Date completed 5-12, 1993

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 18 | 4 | 2 Hrs. |

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 5/8 Inches | 0 Feet | 150 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .188 | +1 | 150 |
| | | | | |

Perforations:
Type perforation Mill
Size perforation 3/32 X 3
From 130 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured

Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 150 feet

9. WATER LEVEL
Static water level 62 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ace Drilling + Development (Contractor)
Address P.O. Box 668 (Contractor)
Silver Springs Nevada 89429
Nevada contractor's license number issued by the State Contractor's Board 14299
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 726
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 5-17-1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627