

OFFICE USE ONLY
 Log No. 4818
 Permit No. 102
 Basin.

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15220

1. OWNER VILLAGE MKT. ADDRESS AT WELL LOCATION 2900 NEVADA ST SILVER SPRINGS NV 89429
 MAILING ADDRESS 2900 NEVADA ST SILVER SPRINGS NV 89429
 2. LOCATION SE 1/4 SW 1/4 Sec 19 T 18 S R 25 E LYON County
 PERMIT NO. MD 15556 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other H.S.A.

6. MW-6 LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|------------------------|--------------|-----------|-----------|------------|
| <u>Loose CLAY Silt</u> | <u>NO</u> | <u>0</u> | <u>5</u> | <u>5</u> |
| <u>SILT CLAY</u> | <u>NO</u> | <u>5</u> | <u>23</u> | |
| <u>FGR Qtz SAND</u> | <u>YES</u> | <u>23</u> | <u>43</u> | |
| <u>HI PLASTIC CLAY</u> | <u>YES</u> | <u>43</u> | <u>45</u> | |

8. WELL CONSTRUCTION
 Depth Drilled 45.0 Feet Depth Cased 45.0 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 Inches To 45' Feet
 From 0 Feet To 45' Feet
 From 0 Feet To 45' Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>2" PVC</u> | | <u>SCH 40</u> | <u>0</u> | <u>45'</u> |

Perforations: Factory Slot
 Type perforation
 Size perforation .020
 From 30' feet to 45' feet
 From 30' feet to 45' feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0-29' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 29' feet to 45' feet

9. WATER LEVEL
 Static water level 38' feet below land surface
 Artesian flow W/A G.P.M. W/A P.S.I.
 Water temperature 61.0 °F Quality W/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Andrew Dilling Contractor
 Address 1635 Belford RD RENO NV 89569 Contractor
 Nevada contractor's license number 34525 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
 Signed [Signature]
 By driller performing actual drilling on site of contractor
 Date 5/11/93

Date started 4-28 1993
 Date completed 4-30 1993

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|------------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | <u>W/A</u> | <u>W/A</u> | |