WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41824
Permit No.
Basin 103

NOTICE OF INTENT NO. 22496

1. OWNER Ken Shelton
MAILING ADDRESS 255 Hico
Dayton NV. 89402
ADDRESS AT WELL LOCATION 255 Hico
Dayton NV.

2. LOCATION SE ¼ SE ¼ Sec. 9 T. 16 N/S R. 23 E. Lyon County
PERMIT NO. N/A (Issued by Water Resources) 16-371-17 (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay and Sand		0	3	3
Boulders and Sand		3	66	63
Boulders and Gravels		66	135	71
Clay and Gravels		135	145	10
Gravels		145	155	10
Clay		155	175	20
Gray Shale		176	230	55
Black Shale with Coarts		230	260	30
Brown Broken Shale		260	280	20

93 MAY 19 A11:32 RECEIVED STATE ENGINEERS OFFICE

Date started 5/8, 1993
Date completed 5/14, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air Developed For 3 Hours. Produced 100+ Gallons per minute		

8. WELL CONSTRUCTION
Depth Drilled 280' Feet Depth Cased +1 to 280' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	50 Feet
8 3/4 Inches	50 Feet	180 Feet
6 1/4 Inches	180 Feet	280 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	188	+1	180'
5.00	16.00	375	175	280'

Perforations:
Type perforation Torch Cut
Size perforation 3/16 x 6 x 6 Rows
From feet to feet
From feet to feet
From 260 feet to 280 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 180' feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature Cold °F Quality Clean

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling LLC (Contractor)
Address P.O. Box 399 (Contractor)
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 5-19-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627