

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23532

1. OWNER GRISWOLD CONSTRUCTION ADDRESS AT WELL LOCATION 718 PAULA CT
 MAILING ADDRESS GARDNERVILLE GARDNERVILLE

2. LOCATION SE 1/4 NE 1/4 Sec. 24 T 12 N R 20 E DOUGLAS County
 PERMIT NO. 29-452-23 RHVENSTROTH Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY w/GRAVEL		0	8	8
CLAY		8	12	4
SANDY CLAY w/GRAVEL		12	17	5
SANDY CLAY		17	48	31
SANDY CLAY w/GRAVEL		48	61	13
SAND w/GRAVEL		61	68	7
CLAY		68	120	52
SANDY CLAY w/GRAVEL		120	133	13
CLAY		133	139	6
SANDY CLAY w/GRAVEL		139	154	15
COARSE SAND w/GRAVEL	✓	154	161	7
SANDY CLAY w/GRAVEL		161	169	8
COARSE SAND w/GRAVEL	✓	169	179	10
SANDY CLAY w/GRAVEL		179	180	1

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>1.88</u>	<u>0</u>	<u>180</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32
 From 160 feet to 180 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 180 feet

9. WATER LEVEL
 Static water level 85 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 6-16, 1993
 Date completed 6-21, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>15</u>	<u>-</u>	<u>4</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV

Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726

Signed Pat J. Moore
 By driller performing actual drilling on site or contractor
 Date 6-21-93

93 JUL -2 AM 117
 RECEIVED
 STATE ENGINEERS OFFICE