

OFFICE USE ONLY  
 Log No. 41837  
 Permit No. 105  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24302

1. OWNER RICHARD DOUD ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS CARSON CITY, NV

2. LOCATION SE 1/4 NE 1/4 Sec 24 T 12 N R 20 E DOUGLAS County DOUGLAS  
 PERMIT NO. \_\_\_\_\_ Parcel No. 29-462-44 Subdivision Name RHUVENSTROTH  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	19	19
SANDY CLAY w/GRAVEL		19	26	7
CLAY		26	65	39
SANDY CLAY		65	72	7
CLAY		72	104	32
SANDY CLAY w/GRAVEL		104	127	23
BOULDERS w/CLAY		127	158	31
SANDY CLAY w/COBBLES		158	167	9
SAND, GRAVEL, COBBLES	✓	167	200	33

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>200</u>

Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 3 X 3/32  
 From 180 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

9. WATER LEVEL  
 Static water level 115 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD. Contractor  
FALLON, NV  
 Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726  
 Signed Paul A. Mooney  
 By driller performing actual drilling on site or contractor  
 Date 6-24-93

Date started 6-21 1993  
 Date completed 6-24 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>15+</u>	<u>—</u>	<u>3</u>

'93 JUL -2 AM 117  
 RECEIVED  
 STATE ENGINEERS OFFICE