

OFFICE USE ONLY
 Log No. 4187
 Permit No. 105
 Basin. 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24270

1. OWNER GREG DYE CONSTRUCTION ADDRESS AT WELL LOCATION 1412 RABBITRUSH
 MAILING ADDRESS GARDNERVILLE GARDNERVILLE

2. LOCATION SE 1/4 SW 1/4 Sec. 36 T. 13 N. R. 20 E. DOUGLAS County
 PERMIT NO. 23-473-36 WILDFLOWER Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY w/COBBLES		0	17	17
SANDY CLAY w/GRAVEL		17	52	35
SANDY CLAY		52	115	63
SANDY CLAY w/GRAVEL		115	151	36
CLAY		151	159	8
SANDY CLAY w/GRAVEL		159	174	15
CLAY		174	189	15
SANDY CLAY w/GRAVEL		189	193	4
CLAY		193	218	25
SANDY CLAY		218	222	4
CLAY		222	242	20
SANDY CLAY		242	253	11
CLAY		253	271	18
SANDY CLAY		271	288	17
SANDY CLAY w/GRAVEL		288	293	5
CLAY		293	297	4
SANDY CLAY		297	304	7
CEMENTED GRAVEL	✓	304	325	21

8. WELL CONSTRUCTION
 Depth Drilled 325 Feet Depth Cased 325 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 325 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>325</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 X 3/32
 From 305 feet to 325 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 325 feet

9. WATER LEVEL
 Static water level 180 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>10+</u>	<u>—</u>	<u>6</u>

Date started 93 5-20, 1993
 Date completed 5-27, 1993

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC. Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV

Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726

Signed Pat J. Moore
 By driller performing actual drilling on site contractor
 Date 5-28-93