

OFFICE USE ONLY  
 Log No. 41876  
 Permit No. 109  
 Basin 109

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17373

1. OWNER RICK DECARLO ADDRESS AT WELL LOCATION 2680 KAYNE  
 MAILING ADDRESS GARDNERVILLE GARDNERVILLE

2. LOCATION SW 1/4 SW 1/4 Sec 34 T 14 N R 20 E DOUGLAS County  
 PERMIT NO. 21-191-08 Parcel No. JOHNSON LANE Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	4	4
SANDY CLAY w/6 GRAVEL		4	76	72
CLAY		76	79	3
SANDY CLAY w/6 GRAVEL		79	93	14
SAND & GRAVEL		93	108	15
CLAY		108	114	6
SANDY CLAY		114	133	19
CLAY		133	136	3
FINE SAND		136	141	5
CLAY		141	143	2
SAND	✓	143	160	17

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 160 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 3 X 3/32  
 From 140 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

9. WATER LEVEL  
 Static water level 18 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

Date started 4-29, 1993  
 Date completed 5-4, 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>-</u>	<u>1</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD Contractor  
FALLON, NV

Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726

Signed Pat J. Mooney  
 By driller performing actual drilling on site or contractor  
 Date 5-4-93

93 MAY 25 AID:38  
 RECEIVED  
 STATE ENGINEERS OFFICE