

OFFICE USE ONLY
 Log No. 41827
 Permit No. _____
 Basin. 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23539

1. OWNER RICK DECARLO ADDRESS AT WELL LOCATION 1677 SIERRA VIEW
 MAILING ADDRESS GARDNERVILLE GARDNERVILLE

2. LOCATION SE 1/4 NW 1/4 Sec. 35 T. 14 N. R. 20 E DOUGLAS County
 PERMIT NO. 21-260-36 Parcel No. JOHNSON LANE Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	3	3
SANDY CLAY		3	17	14
SANDY CLAY w/COBBLES		17	38	21
SANDY CLAY w/GRAVEL		38	143	105
CLAY		143	151	8
SANDY CLAY		151	167	16
CLAY		167	178	11
SANDY CLAY		178	201	23
CLAY		201	210	9
SANDY CLAY		210	222	12
CLAY		222	256	34
SANDY CLAY		256	276	20
SANDY CLAY w/GRAVEL		276	280	4
CLAY		280	328	48
SANDY CLAY w/GRAVEL	✓	328	335	7
SAND + GRAVEL	✓	335	336	1
SANDY CLAY	✓	336	339	3
CLAY		339	340	1

8. WELL CONSTRUCTION
 Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 340 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>340</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32
 From 3.262 feet to 340 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 340 feet

9. WATER LEVEL
 Static water level 215 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>20+</u>	<u>—</u>	<u>6</u>

Date started 4/28, 1993
 Date completed 5/11, 1993

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV

Nevada contractor's license number 27673
 issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726

Signed Pat J. Moore
 By driller performing actual drilling on site or contractor

Date 5-12-93

MAY 25 10:38 AM '93
 STATE ENGINEERS OFFICE