

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23538

1. OWNER PHIL KEHLER ADDRESS AT WELL LOCATION 2721 ESAW
 MAILING ADDRESS GARDNERVILLE GARDNERVILLE

2. LOCATION SW 1/4 NW 1/4 Sec. 35 T. 14 N. R. 20 E. DOUGLAS County
 PERMIT NO. 21-260-31 JOHNSON LANE Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MWD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND w/COBBLES		0	8	8
SANDY CLAY w/COBBLES		8	22	14
SANDY CLAY w/GRAVEL		22	35	13
SANDY CLAY		35	87	52
CLAY		87	91	4
SANDY CLAY		91	225	134
CLAY		225	231	6
SANDY CLAY		231	259	28
CLAY		259	262	3
SANDY CLAY		262	282	20
COARSE SAND w/CLAY		282	295	13
SANDY CLAY		295	316	21
COARSE SAND + GRAVEL	✓	316	320	4
SANDY CLAY		320	321	1

8. WELL CONSTRUCTION
 Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 320 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>320</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32
 From 300 feet to 320 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 320 feet

9. WATER LEVEL
 Static water level 155 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 5-12, 1993
 Date completed 5-19, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>20 +</u>	<u>—</u>	<u>6</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV

Nevada contractor's license number 27673
 issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726

Signed Pat J. Mooney
 By driller performing actual drilling on site contractor

Date 5-20-93