

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20505

1. OWNER ERICH GREIMEISTER ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 226 PEPI DRIVE 3260 VISTA DELICATA
GARDNERVILLE, NV 89410 GARDNERVILLE, NV 89410
 2. LOCATION BLOCK 14 1/4 Sec. 18 T. 10 N. S. R. 22 E. DOUGLAS County
 PERMIT NO. APN 3750210 HELBROOK HIGHLANDS Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Concrete Fill		0	60	
SHARP GRAVEL IN CLAY		60	118	
SHARP GRAV. SM. CLAY		118	138	
CONG. FILL w/ SANDY CLAY		138	180	
CONG. LESS CLAY	WB	180	220	

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
9 7/8" Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		188	220	0

Perforations:
 Type perforation FACTORY
 Size perforation 3/32 x 3"
 From 220 feet to 200 feet
 From 140 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 55' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 132' feet below land surface
 Artesian flow GOOD G.P.M. 12+ P.S.I.
 Water temperature COLD Quality COLD

Date started _____, 19____
 Date completed 4-12, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>12+</u>		<u>5 1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ED MILLER Contractor
 Address BOX 92 Contractor
SMITH, NV 89444
 Nevada contractor's license number 32166
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 15315
 Division of Water Resources, the on-site driller.
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 4-15-93