Plugging

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41152
Permit No.
Basin 104

NOTICE OF INTENT NO. 18237

1. OWNER Glenn Peters
MAILING ADDRESS P.O. Box 246
Wellington, NV 89444

ADDRESS AT WELL LOCATION
3550 Burk Drive Smith, NV

2. LOCATION SW ¼ SW ¼ Sec. 13 T 12 N/S R 23 E Lyon County
PERMIT NO. 13344 (Issued by Water Resources) | na (Parcel No.) | na (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blow sand		0	2	2
Brown clay		2	5	3
Sand		5	7	2
Brown clay		7	10	3
Sand		10	11	1
Blue clay		11	31	20
Sand w/some silt		31	160	129
Sand w/s clay stringers		160	200	40

ABANDON EXISTING WELL
Positioned drill rig.
Installed tremie to
bottom of well. Pumped
neat cement from 110'
to surface.

RECEIVED
STATE ENGINEERS OFFICE
93 MAY -4 A10:23

Date started April 5, 1993
Date completed April 8, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200		6

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
16½ Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.71	.188	0	100

Perforations:
Type perforation Double row mill slot
Size perforation 3½ X 1/8
From 100 feet to 200 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address P.O. Box 590 (Contractor)
Winnemucca, NV 89446
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1448
Signed C. C. Epple (By driller performing actual drilling on site or contractor)
Date 4-30-93

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627