



PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18236 & 1823

1. OWNER Glenn Peters ADDRESS AT WELL LOCATION 3550 Burk Drive Smith, NV  
 MAILING ADDRESS P.O. Box 246 Wellington, NV 89444

2. LOCATION NW 1/4 SW 1/4 Sec. 24 T. 12 N/S R. 23 E Lyon County  
 PERMIT NO. 16798 Issued by Water Resources Parcel No. NA Subdivision Name NA

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Loose surface sand		0	2	2
Sandy clay		2	10	8
Coarse sand		10	19	9
Blue silt		19	21	3
Blue sand w/ silt	X	21	175	154
Blue clay		175	180	5

\*\*\*ABANDON EXISTING WELL\*\*\*  
 Positioned rig, ran tremie pipe to bottom of well. Pumped heavy bentonite up to 50' level. Installed plug. Pumped neat cement from 50' to surface.

23 MAY -4 10:23 RECEIVED STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)  
 From 20 Inches To 180 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/4	33.38	.250	0	80

Perforations:  
 Type perforation Double row mill slot  
 Size perforation 3/2 X 1/8  
 From 80 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 50 feet to 180 feet

Date started March 30, 1993  
 Date completed April 2, 1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
1150	110	8	

9. WATER LEVEL  
 Static water level 15 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Humboldt Drilling & Pump Co., Inc. Contractor  
 Address P.O. Box 590 Winnemucca, NV 89446 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 015234  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1448  
 Signed C. C. Apple By driller performing actual drilling on site or contractor  
 Date 4-30-93